

Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
Kendriya Vidyalaya BSF Sunderbani
District Rajouri

No: JDJF&ES/FP/ 2990

Dated: 23-06.2021

Sub: Provisional Fire Safety Certificate


Ref: Your Letter No. 2157/GEN/KVSB/2021-22/809 dated: 14.06.2021.

Sir,

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed only 01 No. of First Aid Fire Extinguishers in their entire school premises. The school is about 35 Km away from Fire & Emergency Station Nowshera and is approachable for fire appliances in case of any emergency. Since the school is already functioning, as such the management can proceed ahead for operation provisionally subject to adopt the following fire safety measures/guidelines in letter and spirit forthwith for the safety of students studying there:

1. 06 Nos. ABC Stored Pressure Type Fire Extinguishers of 04 Kg capacity each should be provided in the school premises at appropriate locations, 01 No. of CO₂ Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel and 01 No. Clean Agent Type Fire Extinguisher of 02 Kg capacity each should be provided in each computer laboratory in addition to already existing fire extinguishers
2. Fire Alarm System should be provided in the building for alerting inmates during any emergency.
3. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
4. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/operating of fire fighting system installed in the School building. The management shall intimate the office of Assistant Director, Fire & Emergency Services Command Rajouri - Poonch after each quarter that the fire fighting equipments installed in the school are functioning.
5. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
6. The corridor of the building shall not be used for any kind of storage.
7. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this provisional clearance issued will be treated withdrawn/cancelled.
8. One window of each class room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
9. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
10. At present school is having three blocks, all are single storied. As such no addition/alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, this provisional clearance will be treated withdrawn/cancelled.
11. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
12. The validity of this provisional clearance shall remain in force for six months and same needs to be renewed after checking of fire fighting system installed in the school (i.e. existing as well as proposed).

Yours Faithfully


Joint Director

Fire & Emergency Services
Jammu Range, Jammu