



केन्द्रीय विद्यालय सी. सु. बल सुन्दरबनी

KENDRIYA VIDYALAYA BSF SUNDERBANI

शिक्षा मंत्रालय, भारत सरकार के अधीन स्वायत्त निकाय

An Autonomous Body Under Ministry of Education, Govt of India

जिला-राजीरी, जम्मू और कश्मीर / DISTT- RAJOURI, J&K

पिन - 185153, सी.बी.एस.ई संबंधन सं - 700035


PIN 185153, CBSE Aff. No. 700035

F. No. 2157/GEN/KVSB/2021-22/

Dated: 19.04.2021

WATER, HEALTH AND SANITATION CERTIFICATES REGARDING

As Kendriya Vidyalaya BSF Sunderbani is running in temporary building under Sponsoring agency Border Security Force (BSF), Water, Health and sanitation is taking care by them only. BSF is monitoring the quality of potable water regularly. Health Camp for the staff members and students regularly organized in Vidyalaya. Sanitation is also taking care by BSF.


19/4/21
अध्यक्ष/Principal
केन्द्रीय विद्यालय
Principal Kendriya Vidyalaya
सुन्दरबनी/Sunderbani

Contact No: 01960233268, E.mail:- kvsunderbani@gmail.com

Website: <https://bsfsunderbani.kvs.ac.in>

कर्तव्यनिष्ठा दायित्वबोध हमारी पहचान

SAMPLE ID:- NSR/LAB/SP/264

DATE:- 08/02/2020

SOURCE :- DUGWELL WATER [BSF]

S.NO.	PARAMETER	LIMITS	Actual value	Remarks
1	Colour	Acceptable	Acceptable	FIT ✓
2)	Odour	"	"	FIT ✓
3)	PH	6.5-8.5	7.5	FIT ✓
4)	Turbidity	1-5 NTU	1.86 NTU	FIT ✓
5)	Calcium	50-200 mg/L	103 mg/L	FIT ✓
6)	Alkalinity	200-600 mg/L	296 mg/L	FIT ✓
7)	E. coli	Negative	Negative	FIT ✓

Sample is found fit for drinking and other purposes.

Sudashan Kumar
CHEMIST

V. Anurag

What about Testing
Kit 2 other parameters?

✓
12/2